



BUILDING OFFICIAL INTERPRETATION 2018-09
July 01, 2021

CODE/EDITION: VIRGINIA UNIFORM STATEWIDE BUILDING CODE/2018

SECTION(S): ICC A117.1-2009 Accessible and Usable Buildings and Facilities

QUESTION:

1. Is a single toilet restroom required to have a self-closing door?

ANSWERS

1. No.

ICC A117.1-2009, Section 604.9 Wheelchair Accessible Compartment is not applicable to a single toilet restroom. A "compartment" is a toilet stall created by toilet partitions within a multi-toilet restroom. A single toilet restroom is not a "compartment."

A handwritten signature in black ink that reads "Eric M. Mays".

Eric M. Mays, P.E.
Building Official