



Emergency Repair / Maintenance Permit



Permit Requirements

- Submit Emergency Repair/ Maintenance permit checklist and FPP application through the e-Portal
- Application must state scope of work as defined below

EMERGENCY REPAIR PERMIT FOR EXISTING APPROVED SYSTEMS

Sprinkler – up to five heads, up to 20 feet of pipe, one drum drip with valve, one air compressor

Fire Alarm – up to ten devices, 1 FACP if damaged, 1 dialer (like and kind)

U/G Firemain – up to 20 feet of pipe due to damage or freezing

Hood – If activated due to moderate fire or if pipe is broken

MAINTENANCE PERMIT FOR EXISTING APPROVED OR NEW SYSTEMS

Sprinkler – Heads (100%) – nozzles, valves, pipe, drum drip, flow switch, air compressor

Fire Alarm – FACP, NAC panel, initiating devices, notification devices

U/G Fireline – pipe, fittings, valves

Hood – leaking pipe, detection line, pull stations

Fire Pump - replacement

NO MODIFICATIONS TO EXISTING APPROVED SYSTEMS ALLOWED

- All replacement parts must be “like and kind” and remain on site for the inspection.

BENEFITS - No plan review required, minimal fee for one inspection, speedy, code-compliant repairs**

For more information visit our website [here](#):

Fire Marshal’s Office
PWC Department of Fire and Rescue
5 County Complex Ct. #160
Prince William, VA 22192
703-792-6360