

Fire Alarm Express Permit



<u>Fire Alarm Express Permit Requirements</u>

- · Must obtain a fire protection permit.
- Scope of work shall be monitoring the sprinkler flow and tamper switches, adding a fire alarm panel, one smoke detector above the *FACP*, and one alarm device on the exterior of the building.
- Fire alarm installation is still required to comply with **NFPA 72**; equipment listed for fire protection use is required.
- Fire inspection is required (Fire Alarm, Battery Test and Fire Alarm Final).
- During the fire inspection, the contractor is required to provide the following, but not limited to:
 - All fire alarm manufacturer's equipment cutsheets
 - A riser diagram showing the FACP and all devices
 - The location of FACP in the sprinkler room showing that the proper clearance for the FACP
 - The battery calculations
 - The sequence of operation
 - Verification of the connection to the central station

Note: The Fire Alarm Express Permit does not apply to existing fire alarm systems that need to modify the fire alarm panel or any similar alterations. This option will be allowed for all occupancies that only need a fire alarm sprinkler monitoring system.

For more information please visit our website below or contact us at

http://www.pwcgov.org/FMOPlanReview

Fire Marshal's Office
Prince William County
Department of Fire & Rescue
5 County Complex Court
Prince William, VA 22192
703-792-6360